

Wet FGD Mercury Control for Coal-Fired Utility Boilers

SCIENTECH Mercury Emissions Control Workshop
January 22, 2002

Presenter: Kevin E. Redinger, Babcock & Wilcox
Co-Authors: G. Kudlac, G. Amrhein, D. Yurchison, MTI



Babcock & Wilcox



Mercury Control Technology



8 year \$14 million development effort leads to mercury control technology

- Timely
- Cost effective
- Retrofittable
- Integrates with WFGD

B&W's pathway to commercialization



55 MWe long term demonstration at MSCPA, Endicott Station -- May '01

1300 MWe full-scale demonstration at the Zimmer Plant -- Fall '01 (Cinergy, DP&L, AEP)



Development/Demonstration Partners: OCDO & US DOE

US Department of Energy / Ohio Coal Development Office
Babcock & Wilcox / MTI




Wet FGD Mercury Control for Coal-Fired Utility Boilers

B&W Wet SO₂ Scrubber



Wet FGD Mercury Control for Coal-Fired Utility Boilers

Clean Environment Development Facility (CEDF)




Wet FGD Mercury Control for Coal-Fired Utility Boilers

B&W / MTI Pilot Wet Scrubber


Typical Operating Conditions

| | |
|--|---------------------|
| Inlet Gas Flow | 2,100 acfm |
| Slurry pH | 5.4 - 5.6 |
| L/G Ratio | 120 gal / 1,000 acf |
| SO ₂ Removal / Slurry Oxidation | 95% / >99% |



Wet FGD Mercury Control for Coal-Fired Utility Boilers

AECDP Pilot Results - mid 1990's




FGD Design and Operation Impacts Mercury Control



Wet FGD Mercury Control for Coal-Fired Utility Boilers

AECDP Pilot Results - mid 1990's




Oxidized Mercury Removal at 85% to 98%



Wet FGD Mercury Control for Coal-Fired Utility Boilers

AECDP Pilot Results - mid 1990's




Limited Impact on Elemental Mercury



Wet FGD Mercury Control for Coal-Fired Utility Boilers

AECDP Pilot Results - mid 1990's



Favorable oxidized/elemental split does not assure high removal efficiency



Wet FGD Mercury Control for Coal-Fired Utility Boilers

Wet Scrubber Performance Optimization

◆ Additives


- Different reagents
- Different means of injection

◆ Hg Sampling

- Triplicate Ontario Hydro sample trains performed at wet scrubber inlet and outlet for each specific test condition
- Process samples (coal, slurry, ESP ash) collected for each test condition
- PS Analytical Sir Galahad Hg analyzer on-site for qualitative determination of Hg control performance



AECDP WFGD Control Enhancement Results




Effective, convenient method of reagent addition



Wet FGD Mercury Control for Coal-Fired Utility Boilers

Test Series #1 Hg Removal Results




Safe, stable reagent proves effective



Wet FGD Mercury Control for Coal-Fired Utility Boilers

Test Series #2 Hg Removal Results




Alternate reagent provides comparable results



Wet FGD Mercury Control for Coal-Fired Utility Boilers

Full Scale Demonstration Tests




**Mercury Removal
Chemical Addition**



Wet FGD Mercury Control for Coal-Fired Utility Boilers

Reagent Injection Skid for Demonstration Tests




Wet FGD Mercury Control for Coal-Fired Utility Boilers

MSCPA Endicott - 55 MW / Limestone / In-situ oxidation



Wet FGD Mercury Control for Coal-Fired Utility Boilers


Full-Scale Parametric Tests - MSCPA



Wet FGD Mercury Control for Coal-Fired Utility Boilers

Full-Scale Parametric Tests - MSCPA

Parametric Test Performance - Endicott
WFGD Outlet



Wet FGD Mercury Control for Coal-Fired Utility Boilers

Cinergy Zimmer - 1300 MW / Thiosorbic Lime / Ex-situ oxidation



Wet FGD Mercury Control for Coal-Fired Utility Boilers

Fate of Mercury - FGD Byproducts

◆ Mercury found mainly in solid phase

- Filtrate samples - < 0.0005 mg/l
- Solids samples - 0.064 to 0.190 mg/kg
- Suggests mercury not in soluble form (not HgCl_2)

◆ Solids leaching tests (TCLP / HNO_3 / HNO_3 and HCl)


- TCLP results generally non-detect (< 0.21 mg/kg)
- Strong acid digestion suggests mercury not strongly tied to ash or gypsum
- Acids used were much stronger than would be encountered naturally
- No impact of additive observed

◆ Thermal Decomposition Tests

- PSA continuous mercury analyzer
- Mercury appears in the byproduct as HgSO_4 and either HgO and/or HgS




Thermal Decomposition Analysis



Wet FGD Mercury Control for Coal-Fired Utility Boilers

Thermal Decomposition Curve (TDC) for Hg Standards




Wet FGD Mercury Control for Coal-Fired Utility Boilers

TDC for Pilot WFGD Solids

(Baseline - 47% Reduction)

WS-1C Dewatered ART Slurry - 2.2258 g

250 ml/min Ar, 2% SnCl₂ in 5% NaOH, 6°C/min, Test: 112700-1




Wet FGD Mercury Control for Coal-Fired Utility Boilers

TDC for Pilot WFGD Solids

(Alt. Approach 1 - 77% Reduction)

WS-5C Dewatered ART Slurry - 3.2424 g

250 ml/min Ar, 2% SnCl₂ in 5% NaOH, 6°C/min, Test: 111600-3



Wet FGD Mercury Control for Coal-Fired Utility Boilers

EPA ICR Data - Wet FGD Mercury Control

PC Fired Boilers - Baghouse and Wet FGD

| | Wet FGD Mercury Emissions Reduction % | |
|--|--|---------|
| | Range | Average |
| Lignite (No sites) | | |
| Sub-Bituminous (No sites) | | |
| Bituminous (2 sites) | 58 - 86 | 72 |
| Average inlet Hg ⁰ (33% of total) | | |
| Design L/G 60 and 100 gpm/kacfm | | |
| Open spray towers | | |
| 90% SO ₂ removal | | |
| Natural oxidation | | |



EPA ICR Data - Wet FGD Mercury Control

PC Fired Boilers - Cold Side ESP and Wet FGD

Mercury Emissions Reduction %

Range Average

Lignite (2 sites)

21 - 56

44

Average inlet Hg^0 (46%)

Sub-Bituminous (3 sites)

0 - 57

25

High average inlet Hg^0 (72%)

Bituminous (1 site)

62 - 68

64

Average inlet Hg^0 (30%)

Design L/G 138 gpm/acfm

Open spray towers

95% SO_2 removal (Formic acid addition)

Forced oxidation



Wet FGD Mercury Control for Coal-Fired Utility Boilers

EPA ICR Data - Wet FGD Mercury Control

PC Fired Boilers - Hot Side ESP and Wet FGD

Mercury Emissions Reduction %
Range Average

Lignite (No sites)

Sub-Bituminous (5 sites)

3 - 43

29

Average inlet Hg^0 (61%)

Bituminous (1 site)

45 - 53

49

Average inlet Hg^0 (31%)

Outlet Hg^0 +19% over inlet Hg^0

Design L/G 50 gpm/acfm

Venturi tower

52.7% SO_2 removal

Natural oxidation



Wet FGD Mercury Control for Coal-Fired Utility Boilers

EPA Perspective on Wet FGD Mercury Control

◆ Current Level of Control (ICR Data)

| | Bituminous | Sub-bituminous |
|------------|------------|----------------|
| ESP & WFGD | 80 | 0 |
| FF & WFGD | 90 | 75 |

◆ Near-Term Potential (2007 -2008)

| | Bituminous | Sub-bituminous |
|------------|------------|----------------|
| ESP & WFGD | 90 | 50 |
| FF & WFGD | 90 | 85 |

Source: Robert J. Wayland, US EPA ,Northeast Midwest Institute/ECOS Meeting, July, 2001



Wet FGD Mercury Control for Coal-Fired Utility Boilers

OEM Perspective on Wet FGD Mercury Control

- ◆ Mercury control variation may reflect inherent differences in system designs
 - Liquid -to-Gas Ratio (L/G)
 - Tray Tower vs. Open Spray Tower
 - Oxidation (Forced / Natural / Inhibited)
- ◆ Consider FGD design and operation differences in ICR data review
- ◆ 90+% removal potential for bituminous coal
- ◆ Integration of mercury oxidation for low Cl coals needed



Ongoing Wet FGD Mercury Control Work

- ◆ Demonstration test data analysis
- ◆ FGD inlet mercury speciation
 - Mercury oxidation across SCR catalyst tests
 - Fuel and flue gas additives for PRB coal
- ◆ Fate of mercury characterization testing
- ◆ Wet FGD tests on other coal types

